

IKO PLC

Coney Green Road
Clay Cross
Chesterfield S45 9HZ

Tel: 01257 488000 Fax: 01246 868035
e-mail: technical-ikopolymERIC@ikogroup.co.uk
website: www.ikogroup.co.uk



Agrément Certificate
05/4287
Product Sheet 4

IKO WATERPROOFING SYSTEMS

ARMOURPLAN PSG ROOF WATERPROOFING SYSTEM

This Agrément Certificate Product Sheet⁽¹⁾ relates to the Armourplan PSG Roof Waterproofing System, a glass tissue reinforced single-ply PVC fleece-backed membrane for use in adhered waterproofing systems on flat and pitched roofs with limited access.

(1) Hereinafter referred to as 'Certificate'

CERTIFICATION INCLUDES:

- factors relating to compliance with Building Regulations where applicable
- factors relating to additional non-regulatory information where applicable
- independently verified technical specification
- assessment criteria and technical investigations
- design considerations
- installation guidance
- regular surveillance of production
- formal three-yearly review.



KEY FACTORS ASSESSED

Weathertightness — the system will resist the passage of moisture into the building (see section 6).

Behaviour in relation to fire — the system will enable a roof to be unrestricted under Building Regulations (see section 7).

Resistance to wind uplift — the system will resist the effects of any likely wind suction acting on the roof (see section 8).

Resistance to foot traffic — the system will accept the limited foot traffic and loads associated with installation and maintenance (see section 9).

Durability — under normal service conditions the system will provide a durable roof waterproofing with a service life in excess of 30 years (see section 11).

The BBA has awarded this Certificate to the company named above for the system described herein. This system has been assessed by the BBA as being fit for its intended use provided it is installed, used and maintained as set out in this Certificate.

On behalf of the British Board of Agrément

Date of First issue: 2 April 2015

John Albon — Head of Approvals
Construction Products

Claire Curtis-Thomas
Chief Executive

The BBA is a UKAS accredited certification body — Number 113. The schedule of the current scope of accreditation for product certification is available in pdf format via the UKAS link on the BBA website at www.bbacerts.co.uk

Readers are advised to check the validity and latest issue number of this Agrément Certificate by either referring to the BBA website or contacting the BBA direct.

British Board of Agrément
Bucknalls Lane
Watford
Herts WD25 9BA

tel: 01923 665300
fax: 01923 665301
clientservices@bba.star.co.uk
www.bbacerts.co.uk

©2015

Regulations

In the opinion of the BBA, the Armourplan PSG Roof Waterproofing System, if installed, used and maintained in accordance with this Certificate, can satisfy or contribute to satisfying the relevant requirements of the following Building Regulations (the presence of a UK map indicates that the subject is related to the Building Regulations in the region or regions of the UK depicted):



The Building Regulations 2010 (England and Wales) (as amended)

Requirement: B4(2)	External fire spread
Comment:	On suitable non-combustible substructures the use of the system will enable a roof to be unrestricted under this Requirement. See section 7 of this Certificate.
Requirement: C2(b)	Resistance to moisture
Comment:	The system, including joints, will enable a roof to meet this Requirement. See section 6.1 of this Certificate.
Regulation: 7	Materials and workmanship
Comment:	The system is acceptable. See section 11 and the <i>Installation</i> part of this Certificate.



The Building (Scotland) Regulations 2004 (as amended)

Regulation: 8(1)(2)	Durability, workmanship and fitness of materials
Comment:	The use of the system satisfies the requirements of this Regulation. See sections 10 and 11 and the <i>Installation</i> part of this Certificate.
Regulation: 9	Building standards applicable to construction
Standard: 2.8	Spread from neighbouring buildings
Comment:	On suitable substructures, the use of the system will be unrestricted by the requirements, under clause 2.8.1 ⁽¹⁾⁽²⁾ of this Standard. See section 7 of this Certificate.
Standard: 3.10	Precipitation
Comment:	The system will contribute to a roof satisfying clauses 3.10.1 ⁽¹⁾⁽²⁾ and 3.10.7 ⁽¹⁾⁽²⁾ of this Standard. See section 6.1 of this Certificate.
Standard: 7.1(a)	Statement of sustainability
Comment:	The system can contribute to meeting the relevant requirements of Regulation 9, Standards 1 to 6 and therefore will contribute to a construction meeting a bronze level of sustainability as defined in this Standard.
Regulation: 12	Building standards applicable to conversions
Comment:	All comments given for this system under Regulation 9, Standards 1 to 6 also apply to this Regulation, with reference to clause 0.12.1 ⁽¹⁾⁽²⁾ and Schedule 6 ⁽¹⁾⁽²⁾ . (1) Technical Handbook (Domestic). (2) Technical Handbook (Non-Domestic).



The Building Regulations (Northern Ireland) 2012

Regulation: 23(a)(i)(iii)(b)(i)	Fitness of materials and workmanship
Comment:	The system is of an acceptable material. See section 11 and the <i>Installation</i> part of this Certificate.
Regulation: 28(b)	Resistance to moisture and weather
Comment:	The system will contribute to a roof satisfying this Regulation. See section 6.1 of this Certificate.
Regulation: 36(b)	External fire spread
Comment:	On a suitable substructure, the use of the system will enable a roof to be unrestricted under the requirements of this Regulation. See section 7 of this Certificate.

Construction (Design and Management) Regulations 2007

Construction (Design and Management) Regulations (Northern Ireland) 2007

Information in this Certificate may assist the client, CDM co-ordinator, designer and contractors to address their obligations under these Regulations.

See section: 1 *Description* (1.2) and 3 *Delivery and site handling* (3.3) of this Certificate.

Additional Information

NHBC Standards 2014

NHBC accepts the use of the Armourplan PSG Roof Waterproofing System, provided it is installed, used and maintained in accordance with this Certificate, in relation to *NHBC Standards*, Chapter 7.1 *Flat roofs and balconies* and Chapter 7.2 *Pitched roofs*.

CE marking

The Certificate holder has taken the responsibility of CE marking the system in accordance with harmonised European Standard BS EN 13956 : 2012. An asterisk (*) appearing in this Certificate indicates that data shown are given in the manufacturer's Declaration of Performance.

Technical Specification

1 Description

1.1 The Armourplan PSG Roof Waterproofing System is a flexible polyvinyl chloride (PVC) fleece-backed single-ply roof waterproofing membrane, reinforced with glass tissue ($50 \text{ g}\cdot\text{m}^{-2}$) and a non-woven polyester fleece backing ($120 \text{ g}\cdot\text{m}^{-2}$), and available in mid grey and slate grey.

1.2 The membrane is manufactured to the nominal characteristics given below.

Thickness (mm)	1.2
Roll width (mm)	2120
Roll length (m)	20
Weight per unit area* ($\text{g}\cdot\text{m}^{-2}$)	1700
Tensile strength* ($\text{N}\cdot 50 \text{ mm}^{-1}$)	800
Elongation* (%)	150
Tear resistance* (N)	>150
Watertightness*	pass
Foldability at low temperatures* ($^{\circ}\text{C}$)	< -30
Standard colour	mid grey, slate grey
Plasticiser type	phthalate.

1.3 Ancillary items necessary for installation of the system and included in this assessment are:

- IKO Armourplan PVC contact adhesive — a contact adhesive for use at details and upstands
- Spectrabond low foaming PU adhesive — for bonding the roofing membrane to the substrate
- Armourplan Seam Cleaner — preparation solvent for cleaning PVC roofing membranes as required (eg prior to welding)
- IKOpro Systems Bonding Agent — for sealing and preparation of surfaces prior to application of IKO Systems S-A bituminous membranes
- IKOpro Sprayfast FMA — sprayable PU adhesive for bonding the membrane to the substrate
- Armourplan Coated Metal — pre-coated flat metal sheet, 0.6 mm steel with 0.6 mm Armourplan membrane
- IKOfix Peel Stop Bar — steel fixing strip for membrane anchorage
- Systems T-O Underlay — torch-on VCL suitable for use on metal decks (IKOpro Fast Dry Primer required) (subject of BBA Certificate)
- Systems S-A Underlay — VCL suitable for self-adhesive application (IKOpro Systems Bonding Agent required) (subject of BBA Certificate)
- Polimar UV Detailing Liquid — liquid-applied detailing system for complex detailing (subject of BBA Certificate).

1.4 Other items or components which may be used with the system, but which are outside the scope of this Certificate, are:

- Armourplan Detailing Membrane — homogeneous or glass tissue reinforced PVC membrane for complex detailing
- Armourplan Walkway — PVC membrane with slip-resisting surface for use on walkway areas
- Armourplan Cover Strips — glass tissue and polyester scrim reinforced membrane cover strips for butt jointing SG membranes, gutters and detailing
- Armourplan Pre-formed Corners — pre-formed internal and external corners
- Armourplan Outlet Pipes
- Armourplan PVC Standing Seam Profile — pre-formed PVC profile used to simulate a metal standing seam roof
- Armourflow Coated Metal — pre-coated flat metal sheet for fabrication of gutters, 1.2 mm thick steel with 1.2 mm thick Armourplan membrane
- Armourplan Drip Details — pre-fabricated drip details
- Armourplan Chase Termination Details — pre-fabricated chase termination details
- Membrane Pipe & Post Details — pre-fabricated bespoke details formed using Armourplan detailing membrane
- Armourplan P — for forming linear upstand details
- Armourprep — acetone-based preparation solution for PVC roofing membranes with heavy moisture contamination
- IKO PVC refurbishment primer — primer used in conjunction with Spectrabond Low Foaming PU adhesive or IKOpro High Performance PU Adhesive when overlaying existing adhered PVC membrane roofs

- IKOpro High Performance PU Adhesive — high-performance PU adhesive for bonding insulation boards to substrate
- IKOfix Aluminium Clamping Strips — aluminium clamping strip for upstand termination
- IKO Glass Universal Underlay — torch-on VCL suitable for use on concrete decks (IKOpro Fast Dry Primer required)
- Systems T-O VCL — metal-lined vapour barrier, torch-applied (IKOpro Fast Dry Primer required)
- Systems S-A VCL — metal-lined vapour barrier, self-adhesive (IKOpro Systems Bonding Agent required)
- Challenger Polyester 180 Sand — VCL suitable for pour-and-roll application (IKOpro Fast Dry Primer may be required)
- Spectravap — polyethylene vapour control layer
- IKOpro Quick Dry Bitumen Primer — bituminous primer for torch-on and pour-and-roll VCL applications
- Armourplan PVC Sealant — sealant for sealing detail terminations
- Spectratex Separation Layer — polyester separation and protection layer
- IKO Enertherm PIR — polyisocyanurate board with mineral glass tissue facings on both sides, or alternatively coated on both sides with a tri-ply gastight aluminium multi-layer complex.

2 Manufacture

2.1 The membranes are manufactured by an extrusion/calendering process.

2.2 As part of the assessment and ongoing surveillance of product quality, the BBA has:

- agreed with the manufacturer the quality control procedures and product testing to be undertaken
- assessed and agreed the quality control operated over batches of incoming materials
- monitored the production process and verified that it is in accordance with the documented process
- evaluated the process for management of nonconformities
- checked that equipment has been properly tested and calibrated
- undertaken to carry out the above measures on a regular basis through a surveillance process, to verify that the specifications and quality control operated by the manufacturer are being maintained.

2.3 The management system of IKO PLC has been assessed and registered as meeting the requirements of BS EN ISO 9001 : 2008 by BSI (Certificate FM 45901).

3 Delivery and site handling

3.1 The membranes are delivered to site in rolls, wrapped in plastic bearing the product name, manufacturer's name, product dimensions, article number and batch number.

3.2 Rolls should be stored horizontally under cover, off the surface of the roof/substrate and on a clean, level surface.

3.3 IKO Armourplan PVC contact adhesive and Spectrabond PU adhesive (low foaming) are classified under *The Chemicals (Hazard Information and Packaging for Supply) Regulations 2009 (CHIP4)/Classification, Labelling and Packaging of Substances and Mixtures (CLP Regulation) 2009*. The classifications are given in Table 2. These products bear the appropriate hazard warning.

Table 2 Flashpoint and hazard classification

Material	Flashpoint (°C)	Classification
PVC contact adhesive	-17	Highly flammable, Irritant
Spectrabond PU adhesive – low foaming	-18	Highly flammable, Irritant

Assessment and Technical Investigations

The following is a summary of the assessment and technical investigations carried out on the Armourplan PSG Roof Waterproofing System.

Design Considerations

4 Use

4.1 The Armourplan PSG Roof Waterproofing System is satisfactory for use as roof waterproofing in adhered installations on flat and pitched roofs with limited access.

4.2 Limited access roofs are defined for the purpose of this Certificate as those subjected only to pedestrian traffic for maintenance of the roof covering, cleaning of gutters, etc. Where traffic in excess of this is envisaged, additional protection to the membrane must be provided (see section 9).

4.3 Flat roofs are defined for the purpose of this Certificate as those having a minimum finished fall of 1:80. For design purposes, twice the minimum finished fall should be assumed, unless a detailed analysis of the roof is available, including overall and local deflection, direction of falls, etc. Pitched roofs are defined for the purpose of this Certificate as those having a fall greater than 1:6.

4.4 Decks to which the system is to be applied must comply with the relevant requirements of BS 6229 : 2003 or BS 8217 : 2012 and, where appropriate, *NHBC Standards 2014*, Chapter 7.1.

4.5 Insulation materials to be used in conjunction with the membranes must be in accordance with the Certificate holder's instructions and be either:

- as described in the relevant clauses of BS 8217 : 2012, or
- the subject of a current BBA Certificate and used in accordance with, and within the scope of, that Certificate.

4.6 Contact with bituminous, coal tar and oil-based products must be avoided, as the membrane is not compatible with lower grades of bitumen. If contact with such products is likely, a separating layer must be interposed before installing the waterproofing sheet. Where doubt arises, the advice of the Certificate holder should be sought.

5 Practicability of installation

Installation must be carried out only by installers trained and approved by the Certificate holder.

6 Weathertightness



6.1 The membrane, including joints, when completely sealed and consolidated, will adequately resist the passage of moisture into the building and enable a roof to comply with the requirements of the national Building Regulations.

6.2 The membrane is impervious to water and will achieve a weathertight roof capable of accepting minor structural movement.

7 Behaviour in relation to fire



7.1 When classified in accordance with BS EN 13501-5 : 2005, a system comprising a 0.7 mm trapezoidal steel deck, a 2 mm self-adhesive Systems S-A vapour control layer, a 130 mm PIR Enertherm insulation bonded with IKOpro High Performance PU adhesive, and a layer of Armourplan PSG, fully bonded with Spectrabond Low Foaming PU adhesive, achieved a B_{ROOF}(t4) rating.

7.2 The designation of other specifications (eg when used on combustible substrates) should be confirmed by:

England and Wales — Requirement B4(2)

Scotland — Mandatory standard 2.8 clauses 2.8.1 and Annex 2.C

Northern Ireland — Regulation 36(b).

8 Resistance to wind uplift

8.1 When bonded to a decking or bituminous felt, the system should have sufficient adhesion to resist the effects of wind suction, elevated temperature and thermal shock conditions likely to occur in practice.

8.2 When adhered to insulation boards, the resistance to wind uplift will be dependent on the cohesive strength of the insulation and the method by which it is secured to the roof deck. This should be taken into account when the insulation material is selected.

9 Resistance to foot traffic

Results of tests indicate that the system can accept the limited foot traffic and light concentrated loads associated with installation and maintenance. Reasonable care should be taken to avoid puncture by sharp objects or concentrated loads. Where traffic in excess of this is envisaged, such as for maintenance of lift equipment, a walkway should be provided, for example, using concrete slabs supported on bearing pads.

10 Maintenance



10.1 The system must be the subject of annual inspection and maintenance to ensure continued performance.

10.2 Maintenance should include checks and operations to ensure the following:

- exposed membrane is free from the build-up of silt and other debris
- integrity of the joints in the membrane
- integrity of the detailing.

10.3 Where damage has occurred, it should be repaired in accordance with section 15 and the Certificate holder's instructions.

11 Durability



11.1 Accelerated weathering tests and evidence from existing installations confirm that satisfactory retention of physical properties is achieved. Under normal service conditions, the system will provide a durable roof waterproofing with a service life in excess of 30 years.

11.2 In environments where the membrane is in contact with organic solvents, its service life may be reduced. In cases of doubt, the advice of the Certificate holder should be sought.

12 General

12.1 Installation of the Armourplan PSG Roof Waterproofing System must be carried out in accordance with the relevant clauses of the Certificate holder's instructions, BS 8000-4 : 1989 and this Certificate.

12.2 Substrates to which the membrane is to be applied must be sound, dry, clean and free from sharp projections such as nail heads and concrete nibs.

12.3 Installation should not be carried out during inclement weather (eg rain, fog or snow). Spectrabond low foaming PU adhesive should not be used in temperatures below 5°C. When the temperature is below 0°C, suitable precautions against surface condensation must be taken in accordance with the Certificate holder's instructions.

13 Procedure

13.1 The membrane is adhered to an acceptable substrate with Spectrabond low foaming PU adhesive. The adhesive is applied to the substrate at a rate of 150–400 g·m⁻², dependent on application method.

13.2 The membrane is laid over the tacky adhesive and smoothed into it.

14 Jointing and flashing procedure

Hot-air welding

14.1 The welding area must be dry and clean. If the membrane in the weld area has become contaminated, it must be cleaned in accordance with the Certificate holder's instructions.

14.2 Welding may be achieved by automatic or hand-operated machines in accordance with the Certificate holder's instructions.

14.3 The welded width of the joint must be a minimum of 30 mm when welded with an automatic welding machine and a 40 mm final weld width when welded with hand-operated machines. On completion of the weld, the seam should be tested with a suitable metal probe, and any weakness repaired immediately.

Flashing

14.4 Flashing and detailing should be carried out in accordance with the Certificate holder's instructions.

15 Repair

In the event of damage, repairs can be carried out by cleaning the area around the damage and applying a patch as per the Certificate holder's instructions.

Technical Investigations

16 Tests

16.1 An assessment was made of data to EN 13956 : 2012 in relation to the following:

- dimensions*
- mass per unit area*
- tensile strength and elongation*
- dimensional stability*
- resistance to tear*
- low temperature foldability*
- resistance to impact*
- resistance to static load*
- watertightness*
- joint peel resistance*
- joint shear resistance*.

16.2 Tests were carried out by the BBA and the results assessed to determine:

- resistance to wind uplift
- peel resistance from support
- in order to assess properties when installed.

17 Investigations

17.1 Existing data on fire performance of the membrane were assessed.

17.2 Durability data of the Armourplan material (see Product Sheet 1) manufactured using the same compound was evaluated to assess the durability of the product under normal service conditions.

17.3 The manufacturing process was evaluated, including the methods adopted for quality control, and details were obtained of the quality and composition of materials used.

Bibliography

BS 6229 : 2003 *Flat roofs with continuously supported coverings — Code of practice*

BS 8000-4 : 1989 *Workmanship on building sites — Code of practice for waterproofing*

BS 8217 : 2012 *Reinforced bitumen membranes for roofing — Code of practice*

BS EN 13501-5 : 2005 *Fire classification of construction products and building elements — Classification using data from external fire exposure to roofs tests*

BS EN 13956 : 2012 *Flexible sheet for waterproofing — Plastic and rubber sheets for roof waterproofing — Definitions and characteristics*

BS EN ISO 9001 : 2008 *Quality management systems — Requirements*

18 Conditions

18.1 This Certificate:

- relates only to the product/system that is named and described on the front page
- is issued only to the company, firm, organisation or person named on the front page — no other company, firm, organisation or person may hold or claim that this Certificate has been issued to them
- is valid only within the UK
- has to be read, considered and used as a whole document — it may be misleading and will be incomplete to be selective
- is copyright of the BBA
- is subject to English Law.

18.2 Publications, documents, specifications, legislation, regulations, standards and the like referenced in this Certificate are those that were current and/or deemed relevant by the BBA at the date of issue or reissue of this Certificate.

18.3 This Certificate will remain valid for an unlimited period provided that the product/system and its manufacture and/or fabrication, including all related and relevant parts and processes thereof:

- are maintained at or above the levels which have been assessed and found to be satisfactory by the BBA
- continue to be checked as and when deemed appropriate by the BBA under arrangements that it will determine
- are reviewed by the BBA as and when it considers appropriate.

18.4 The BBA has used due skill, care and diligence in preparing this Certificate, but no warranty is provided.

18.5 In issuing this Certificate, the BBA is not responsible and is excluded from any liability to any company, firm, organisation or person, for any matters arising directly or indirectly from:

- the presence or absence of any patent, intellectual property or similar rights subsisting in the product/system or any other product/system
- the right of the Certificate holder to manufacture, supply, install, maintain or market the product/system
- actual installations of the product/system, including their nature, design, methods, performance, workmanship and maintenance
- any works and constructions in which the product/system is installed, including their nature, design, methods, performance, workmanship and maintenance
- any loss or damage, including personal injury, howsoever caused by the product/system, including its manufacture, supply, installation, use, maintenance and removal
- any claims by the manufacturer relating to CE marking.

18.6 Any information relating to the manufacture, supply, installation, use, maintenance and removal of this product/system which is contained or referred to in this Certificate is the minimum required to be met when the product/system is manufactured, supplied, installed, used, maintained and removed. It does not purport in any way to restate the requirements of the Health and Safety at Work etc. Act 1974, or of any other statutory, common law or other duty which may exist at the date of issue or reissue of this Certificate; nor is conformity with such information to be taken as satisfying the requirements of the 1974 Act or of any statutory, common law or other duty of care.