# IKO PLC

Prospect Quarry Water Lane Grangemill Derbyshire DE4 4BW Tel: 01257 256888 e-mail: technical.uk@iko.com website: www.ikogroup.co.uk



Agrément Certificate 03/4009 Product Sheet 3

# PERMATEC HOT-APPLIED MONOLITHIC ROOFING AND WATERPROOFING SYSTEMS

# PERMATEC ECOWRAP AND PERMATEC ANTI-ROOT HOT-APPLIED MONOLITHIC MEMBRANE GREEN ROOF WATERPROOFING SYSTEMS

This Agrément Certificate Product Sheet<sup>(1)</sup> relates to PermaTEC EcoWrap and PermaTEC Anti-Root Hot-Applied Monolithic Membrane Green Roof Waterproofing Systems, for use as waterproofing layers in green roofs and roof gardens.

(1) Hereinafter referred to as 'Certificate'.

#### CERTIFICATION INCLUDES:

- factors relating to compliance with Building Regulations where applicable
- factors relating to additional non-regulatory information where applicable
- independently verified technical specification
- assessment criteria and technical investigations
- design considerations
- installation guidance
- regular surveillance of production
- formal three-yearly review.

#### **KEY FACTORS ASSESSED**

Weathertightness — the systems will resist the passage of moisture into the building (see section 7).

**Properties in relation to fire** — the use of the systems will enable a roof to be unrestricted under the Building Regulations (see section 8).

**Resistance to wind uplift** — the systems will resist the effects of any likely wind suction acting on the roof (see section 9). **Resistance to foot traffic** — the systems will accept the limited foot traffic and loads associated with installation and maintenance (see section 10).

**Resistance to penetration by roots** — the systems will resist the effects of root penetration from green roof and roof garden specifications (see section 11).

**Durability** — under normal service conditions the systems will remain waterproof for the design service life of the roof in which they are incorporated (see section 13).

The BBA has awarded this Certificate to the company named above for the systems described herein. These systems have been assessed by the BBA as being fit for their intended use provided they are installed, used and maintained as set out in this Certificate.

On behalf of the British Board of Agrément

## Date of Fourth issue: 25 February 2016

John Albon — Head of Approvals

1.an

Claire Curtis-Thomas Chief Executive

Originally certificated on 27 April 2010

The BBA is a UKAS accredited certification body — Number 113. The schedule of the current scope of accreditation for product certification is available in pdf format via the UKAS link on the BBA website at www.bbacerts.co.uk

**Construction Products** 

Readers are advised to check the validity and latest issue number of this Agrément Certificate by either referring to the BBA website or contacting the BBA direct.

British Board of Agrément		tel: 01923 665300
Bucknalls Lane		fax: 01923 665301
Watford		clientservices@bba.star.co.uk
Herts WD25 9BA	©2016	www.bbacerts.co.uk



# Regulations

In the opinion of the BBA, PermaTEC EcoWrap and PermaTEC Anti-Root Hot-Applied Monolithic Membrane Green Roof Waterproofing Systems, if installed, used and maintained in accordance with this Certificate, can satisfy or contribute to satisfying the relevant requirements of the following Building Regulations (the presence of a UK map indicates that the subject is related to the Building Regulations in the region or regions of the UK depicted):

5 The	e Building R	egulations 2010 (England and Wales) (as amended)	
Requirement:	B4(2)	External fire spread	
Comment:		In green roof and roof garden specifications, the systems will enable a roof to be unrestricted under this Requirement. See sections 8.1 and 8.3 of this Certificate.	
Requirement:	C2(b)	Resistance to moisture	
Comment:		Tests for water resistance indicate that the systems will enable a roof to satisfy this Requirement. See section 7.1 of this Certificate.	
Regulation:	7	Materials and workmanship	
Comment:		The systems are acceptable. See section 13 and the Installation part of this Certificate.	
The Building (Scotland) Regulations 2004 (as amended)			

El so		
Regulation:	8(1)	Durability, workmanship and fitness of materials
Comment:		The use of the systems satisfies the requirements of this Regulation. See section 13 and the <i>Installation</i> part of this Certificate.
Regulation:	9	Building standards applicable to construction
Standard:	2.8	Spread from neighbouring buildings
Comment:		In green roof and roof garden specifications, the systems will enable a roof to be unrestricted under this Standard, and the roof can be regarded as having low vulnerability under clause 2.8.1 <sup>(1)(2)</sup> . See sections 8.1 and 8.3 of this Certificate.
Standard:	3.10	Precipitation
Comment:		Tests for water resistance indicate that the systems will enable a roof to meet the requirements of this Standard, with reference to clauses 3.10.1 <sup>(1)(2)</sup> and 3.10.7 <sup>(1)(2)</sup> . See section 7.1 of this Certificate.
Standard:	7.1(a)	Statement of sustainability
Comment:		The systems can contribute to meeting the relevant requirements of Regulation 9, Standards 1 to 6 and therefore will contribute to a construction meeting a bronze level of sustainability as defined in this Standard
Regulation:	12	Building standards applicable to conversions
Comment:		All comments given for these systems under Regulation 9, Standards 1 to 6 also apply to this Regulation, with reference to clause 0.12.1 <sup>(1)(2)</sup> and Schedule 6 <sup>(1)(2)</sup> . (1) Technical Handbook (Domestic).
		(2) Technical Handbook (Non-Domestic).

E Frank		
Regulation:	23(a)(b)(i)	Fitness of materials and workmanship
Comment:		The systems are acceptable. See section 13 and the <i>Installation</i> part of this Certificate.
Regulation:	28(b)	Resistance to moisture and weather
Comment:		Tests for water resistance indicate that the systems will enable a roof to satisfy the requirements of this
		Regulation. See section 7.1 of this Certificate.
Regulation:	36(b)	External fire spread
Comment:		In green roof and roof garden specifications, the systems will enable a roof to be unrestricted under the requirements of this Regulation. See section 8.1 and 8.3 of this Certificate.

### Construction (Design and Management) Regulations 2015

#### Construction (Design and Management) Regulations (Northern Ireland) 2007

45 The Building Regulations (Northern Ireland) 2012 (as amended)

Information in this Certificate may assist the client, Principal Designer/CDM co-ordinator, designer and contractors to address their obligations under these Regulations.

3 Delivery and site handling (3.1, 3.3 and 3.4) and 15 Procedure (15.3) of this Certificate.

# Additional Information

## NHBC Standards 2016

See sections:

NHBC accepts the use of PermaTEC EcoWrap and PermaTEC Anti-Root Hot-Applied Monolithic Membrane Green Roof Waterproofing Systems, provided they are installed, used and maintained in accordance with this Certificate, in relation to NHBC Standards, Chapter 7.1 Flat roofs and balconies.

## **1** Description

1.1 PermaTEC EcoWrap and PermaTEC Anti-Root Hot-Applied Monolithic Membrane Green Roof Waterproofing Systems include PermaTEC EcoWrap and PermaTEC Anti-Root Membranes, formulated from a combination of refined bitumen, synthetic rubbers and other additives. PermaTEC Anti-Root Membrane also incorporates a root inhibitor. The membranes are applied in two layers to provide a waterproofing layer with a nominal coating thickness of 6 mm.

1.2 The two main system build-ups used for green roof and roof garden applications are:

- PermaTEC EcoWrap membrane incorporating PermaFLASH-R reinforcement finished with a layer of Permatorch Anti-Root
- PermaTEC Anti-Root membrane incorporating PermaFLASH-R reinforcement finished with a layer of PermaGUARD F.

1.3 The membranes are used in conjunction with a range of reinforcement membranes and protection membranes and boards, including:

- PermaFLASH-R − a 55 g·m<sup>-2</sup> polyester reinforcing scrim
- PermaFLASH-D150 a 1.25 mm thick and 150 mm wide flexible detailing sheet, used as a reinforcement layer over cracks, construction joints and changes in materials, and where minor movement may occur
- PermaFLASH-D500 a 1.25 mm thick and 500 mm wide flexible detailing sheet, used as a reinforcement at rainwater outlets
- PermaGUARD-F a 180 g·m<sup>-2</sup> sand-surfaced, polyester-based bitumen membrane protection layer
- PermaGUARD-M a 180 g·m<sup>-2</sup> slate-surfaced, high-performance torch-applied bitumen membrane protection layer for use on details which will not be covered by the surface finishes
- PermaGUARD-HDPB a high-density polymeric protection board
- PermaGUARD-PB a protection board fabricated with a bituminous core sandwiched between two layers of nonwoven glassfibre reinforcement
- Permatorch Anti-Root a slate-surfaced, polyester-based, APP modified bitumen containing a root inhibitor, installed as a protection layer in green roof specifications
- IKOpro PermaTEC High Penetration Primer a brush- or roller-applied bituminous priming solution used in the preparation of cementitious surfaces prior to the application of the membrane
- IKO PermaTEC Polymer Primer a brush- or roller-applied synthetic rubber-based priming solution used in the preparation of cementitious surfaces prior to the application of the membrane.

1.4 Other products which may be used with the systems, but which are outside the scope of this Certificate, include:

- IKO Plasdrain drainage board available in thicknesses of 6 mm, 12 mm and 20 mm
- IKO Enertherm XPS extruded polystyrene insulation used in combination with IKO Enertherm Water Control Layer in inverted/protected roofs including intensive/extensive green roofs
- proprietary expansion joint systems
- IKOgreen Sedum Blanket for use in roof garden applications
- IKOgreen Growing Medium for use in roof garden applications
- IKOgreen Plasfeed 20 for use in roof garden applications.

## 2 Manufacture

2.1 The PermaTEC EcoWrap and PermaTEC Anti-Root compounds are manufactured by heating and blending bitumen, process oils, fillers and other additives in a temperature-controlled cycle. Protection membranes are manufactured by traditional continuous coating processes, and other components of the system are purchased to agreed specifications.

2.2 As part of the assessment and ongoing surveillance of product quality, the BBA has:

- agreed with the manufacturer the quality control procedures and product testing to be undertaken
- assessed and agreed the quality control operated over batches of incoming materials
- monitored the production process and verified that it is in accordance with the documented process
- evaluated the process for management of nonconformities
- checked that equipment has been properly tested and calibrated
- undertaken to carry out the above measures on a regular basis through a surveillance process, to verify that the specifications and quality control operated by the manufacturer are being maintained.

2.3 The management system of IKO PLC has been assessed and registered as meeting the requirements of BS EN ISO 9001 : 2008 by BSI (Certificate FM 595512).

## 3 Delivery and site handling

3.1 The PermaTEC Anti-Root and PermaTEC EcoWrap compounds are delivered to site in 12 kg blocks covered with EcoWrap heat-dispersible film.

3.2 Reinforcing and protection layers are packaged with labels bearing the product trade name and should be stored under cover and kept dry.

3.3 IKOpro PermaTEC High Penetration Primer is delivered to site in 25 litre cans.

3.4 The Certificate holder has taken the responsibility of classifying and labelling the system components under the *CLP Regulation (EC) No 1272/2008 on the classification, labelling and packaging of substances and mixtures.* Users must refer to the relevant Safety Data Sheet(s).

# Assessment and Technical Investigations

The following is a summary of the assessment and technical investigations carried out on PermaTEC EcoWrap and PermaTEC Anti-Root Hot-Applied Monolithic Membrane Green Roof Waterproofing Systems.

# Design Considerations

# 4 Environmental information

4.1 The Permatec EcoWrap and PermaTEC Anti-Root waterproofing membrane compounds have a recycled content of 45% by mass of the total product.

4.2 The recycled materials are described as limestone filler and ground rubber crumb, the latter manufactured from post-consumer vehicular tyres. Post-consumer material is defined in BS EN ISO 14021 : 2001, and the Waste & Resources Action Programme (WRAP) 'Rules of Thumb' Guide to Recycled Content in Construction Products.

4.3 The recycled content has been calculated in accordance with BS EN 14021 : 2001 by expressing the input mass of recycled material as a percentage of the total input mass for the product.

4.4 The source and quantity of recycled material added to the product is verified by the BBA as part of post-Certification auditing.

# 5 Use

5.1 PermaTEC EcoWrap and PermaTEC Anti-Root Hot-Applied Monolithic Membrane Green Roof Waterproofing Systems are satisfactory for use in green roofs with limited access, and roof garden waterproofing systems on flat (including zero-pitched) roofs.

5.2 Limited access roofs are defined for the purpose of this Certificate as those subjected only to pedestrian traffic for maintenance of the roof covering, cleaning of gutters, etc. Where traffic in excess of this is envisaged, additional protection to the systems must be provided (see section 10).

5.3 Flat roofs are defined for the purpose of this Certificate as those having a minimum finished fall of between 1:80 and 1:6. For design purposes, twice the minimum fall should be assumed, unless a detailed analysis of the roof is available, including overall and local deflection, direction of falls etc. Zero-pitched roofs are defined for the purpose of this Certificate as those roofs having a finished fall of less than 1:80.

5.4 Structural decks to which the systems are to be applied must comply with the relevant requirements of BS 6229 : 2003 and must be suitable to transmit the dead and imposed loads experienced in service.

5.5 Imposed loads, dead loads and wind loading are calculated in accordance with BS EN 1991-1-1: 2002, BS EN 1991-1-3 : 2003, BS EN 1991-1-4 : 2005 and their respective UK National Annexes.

5.6 Drainage systems must be correctly designed and provision made for access for maintenance purposes. Blocked drains can cause waterlogging of the drainage and soil layers, thereby increasing dead loads.

5.7 Insulation materials used in conjunction with the system must be of a suitable extruded polystyrene (XPS) in accordance with the manufacturer's instructions.

# 6 Practicability of installation

The systems should only be installed by contractors who have been trained and approved by the Certificate holder. Details of these are available from the Certificate holder.

# 7 Weathertightness

7.1 Results of tests confirm that the systems will adequately resist the passage of moisture into the building and enable a roof to comply with the relevant requirements of the national Building Regulations.

7.2 The systems are impervious to water and will achieve a weathertight roof capable of accepting minor movement.

# 8 Properties in relation to fire



🐲 8.1 In the opinion of the BBA, the systems, when used in irrigated green roofs or roof gardens, will be unrestricted under the national Requirements:

England and Wales — Requirement B4(2), Section 6

Scotland – Mandatory Standard 2.8, clause 2.8.1

Northern Ireland — Regulation 36(b).

8.2 If allowed to dry, plants used in a roof garden may allow flame spread across the roof. This should be taken into consideration when selecting suitable plants for the roof. Appropriate planting irrigation and/or protection should be applied to ensure that the overall fire-rating of the roof is not compromised.



1.3 The designation of other specifications should be confirmed by:

England and Wales — test or assessment in accordance with Approved Document B, Appendix A, clause 1

Scotland — test to conform to Mandatory Standard 2.8, clause 2.8.1

Northern Ireland — test or assessment by a UKAS-accredited laboratory, or an independent consultant with appropriate experience.

### 9 Resistance to wind uplift

9.1 PermaTEC EcoWrap and PermaTEC Anti-Root Hot-Applied Monolithic Membrane Green Roof Waterproofing Systems will resist the effects of wind suction likely to occur in service.

9.2 The soil used in roof gardens should not be of a type that will be removed or become delocalised owing to wind scour experienced on the roof.

9.3 It should be recognised that the type of plants used in roof gardens could significantly affect the expected wind loads experienced in service.

### 10 Resistance to foot traffic

Tests indicate that the systems can accept the limited foot traffic and light concentrated loads associated with installation and maintenance. Reasonable care should be taken to avoid puncture by sharp objects or concentrated loads. Where traffic in excess of this is envisaged, such as for maintenance of lift equipment, a walkway should be provided.

### 11 Resistance to penetration by roots

11.1 Tests on Permatorch Anti-Root cap sheet indicate that it is suitable for use as a root-resistant membrane and, when used with the PermaTEC systems in roof garden applications, will provide adequate protection from penetration by roots.

11.2 PermaTEC Anti-Root Hot-Applied Monolithic Membrane Waterproofing Systems will provide adequate protection from penetration by roots.

11.3 Advice on suitable planting specifications must be sought from the Certificate holder.

### 12 Maintenance

Roofs must be the subject of regular inspections, particularly in autumn after leaf fall and in spring to ensure that unwanted vegetation and other debris are cleared from the roof and drainage outlets are clear. Guidance is available within the latest edition of The GRO Green Roof Code – Green Roof Code of Best Practice for the UK.

## 13 Durability

🖢 PermaTEC EcoWrap and PermaTEC Anti-Root Hot-Applied Monolithic Membrane Green Roof Waterproofing Systems, when fully protected and subjected to normal service conditions, will provide an effective barrier to the transmission of moisture for the design service life of the roof in which they are incorporated.

# Installation

### 14 General

14.1 PermaTEC EcoWrap and PermaTEC Anti-Root Hot-Applied Monolithic Membrane Green Roof Waterproofing Systems must be installed in accordance with the Certificate holder's instructions and this Certificate, on a dry and frostfree substrate. After rain or snow, the substrate must be allowed to dry before installation can commence. The installer can aid drying by any suitable means approved by the Certificate holder. Once applied, the membranes are not affected by rain, snow or frost.

14.2 To assess the suitability of a substrate to receive the systems, bond tests must be carried out to ensure that adequate adhesion can be achieved. If bonding problems occur, advice must be sought from the Certificate holder. 14.3 Prior to the application of the systems, defects in the substrate such as cracks, irregularities and other areas of potential weakness must be repaired using an approved repair mortar, and the substrate cleaned in accordance with the Certificate holder's instructions. Additional membrane may be used to fill minor depressions in the substrate.

14.4 Cementitious substrates must be coated with IKOpro PermaTEC High Penetration Primer (at a nominal coverage rate between 6 m<sup>2</sup> per litre and 8 m<sup>2</sup> per litre) and allowed to dry before application of the systems.

14.5 The systems are covered by a protective layer immediately after installation, in accordance with the Certificate holder's instructions.

14.6 Soil or other bulk material should not be stored on one area of the roof prior to installation, to ensure that localised overloading does not occur.

14.7 Detailing must be formed in accordance with the Certificate holder's instructions.

### 15 Procedure

15.1 Blocks of the membrane compound are heated in a mechanically-agitated melter, which must have a double jacket containing either air or a heat-transfer mineral oil, and be fitted with thermometers to measure the melt and air/oil temperatures.

15.2 The nominal temperature range for the molten membrane is 160°C to 180°C. The temperature of the melt must not exceed 200°C.

15.3 The molten membrane is discharged from the melter into a suitable container and applied to the roof, using a long-handled squeegee for horizontal surfaces and a suitable spreader for vertical surfaces.

15.4 At structural movement joints between 12 mm and 50 mm (maximum 50% total movement), a proprietary joint system must be installed. The Certificate holder should be consulted for suitable products.

15.5 At all non-monolithic changes in substrate materials, at structural/shrinkage cracks between 3 mm and 6 mm wide, at structural joints between 6 mm and 12 mm wide and where minor movement may occur, a reinforcement layer of PermaFLASH-D150 should be applied prior to applying the PermaTEC EcoWrap Anti-Root system.

15.6 At all board joints in plywood, calcium silicate and composite metal decks, a reinforcement layer of PermaFLASH-D150 or a minimum 150 mm wide strip of PermaFLASH-R must be applied prior to applying the membrane. The advice of the Certificate holder should be sought.

15.7 The first layer of the molten membrane should have a nominal thickness of 3 mm.

15.8 PermaFLASH-R polyester reinforcing scrim is embedded by lightly brushing it into the first layer of the membrane whilst it is still hot and tacky. The reinforcement overlaps must be at least 75 mm and fully sealed by the membrane.

15.9 The second layer of membrane, applied over the top of the reinforcement, should have a nominal thickness of 3 mm.

15.10 The membrane must be protected immediately with the specified PermaGUARD or Permatorch Anti-Root protection layer. This is carried out prior to applying the insulation, water control layer and the protective layer or other specified surface finish (see Figure 1 for typical design specifications).





# 16 Repair

16.1 Any damage to the systems must be repaired as soon as possible to ensure that the integrity of the waterproofing is maintained. The advice of the Certificate holder should be sought.

16.2 Where maintenance or repair of any of the roof components above the waterproofing system is necessary, care must be taken to avoid damage to the membrane. If damage to the membrane occurs, it should be repaired in accordance with the Certificate holder's instructions.

16.3 In the event that the systems are contaminated by chemicals, oils and greases the advice of the Certificate holder should be sought.

**Technical Investigations** 

## 17 Tests

17.1 Characterisation tests were carried out on the compound to establish fines, penetration, flow and resilience.

17.2 Characterisation tests were carried out on PermaFlash-R and Permaflash-D to establish thickness, mass per unit area and tensile properties.

17.3 Tests were conducted on samples of the system and/or system components, and the results assessed to determine:

- water vapour permeability
- watertightness
- low temperature flexibility
- resistance to fatigue
- resistance to dynamic indentation (system including Permaguard-PB protection)
- resistance to static indentation (system including Permaguard-PB protection)
- effect of heat ageing
- effect of exposure to surface water
- resistance to penetration by roots.

## 18 Investigations

18.1 The manufacturing process was evaluated, including the methods adopted for quality control, and details were obtained of the quality and composition of the materials used.

18.2 The results of the root resistance testing to German FLL standard were assessed.

# Bibliography

BS 6229 : 2003 Flat roofs with continuously supported coverings - Code of practice

BS EN 1991-1-1 : 2002 Eurocode 1 : Actions on structures — General actions— Densities, self-weight, imposed loads for buildings

NA to BS EN 1991-1-1 : 2002 UK National Annex to Eurocode 1 : Actions on structures — General actions— Densities, self-weight, imposed loads for buildings

BS EN 1991-1-3 : 2003 Eurocode 1 — Actions on structures — General actions — Snow loads

NA to BS EN 1991-1-3 : 2003 UK National Annex to Eurocode 1 : Actions on structures — General actions — Snow loads

BS EN 1991-1-4 : 2005 Eurocode 1 : Actions on structures — General actions — Wind actions NA to BS EN 1991-1-4 : 2005 UK National Annex to Eurocode 1 : Actions on structures — General actions — Wind actions

BS EN 14021 : 2001 + A1 : 2011 Environmental labels and declarations — Self-declared environmental claims (Type II environmental labelling)

BS EN ISO 9001 : 2008 Quality management systems - Requirements

# **19 Conditions**

19.1 This Certificate:

- relates only to the product/system that is named and described on the front page
- is issued only to the company, firm, organisation or person named on the front page no other company, firm, organisation or person may hold or claim that this Certificate has been issued to them
- is valid only within the UK
- has to be read, considered and used as a whole document it may be misleading and will be incomplete to be selective
- is copyright of the BBA
- is subject to English Law.

19.2 Publications, documents, specifications, legislation, regulations, standards and the like referenced in this Certificate are those that were current and/or deemed relevant by the BBA at the date of issue or reissue of this Certificate.

19.3 This Certificate will remain valid for an unlimited period provided that the product/system and its manufacture and/or fabrication, including all related and relevant parts and processes thereof:

- are maintained at or above the levels which have been assessed and found to be satisfactory by the BBA
- continue to be checked as and when deemed appropriate by the BBA under arrangements that it will determine
- are reviewed by the BBA as and when it considers appropriate.

19.4 The BBA has used due skill, care and diligence in preparing this Certificate, but no warranty is provided.

19.5 In issuing this Certificate, the BBA is not responsible and is excluded from any liability to any company, firm, organisation or person, for any matters arising directly or indirectly from:

- the presence or absence of any patent, intellectual property or similar rights subsisting in the product/system or any other product/system
- the right of the Certificate holder to manufacture, supply, install, maintain or market the product/system
- actual installations of the product/system, including their nature, design, methods, performance, workmanship and maintenance
- any works and constructions in which the product/system is installed, including their nature, design, methods, performance, workmanship and maintenance
- any loss or damage, including personal injury, howsoever caused by the product/system, including its manufacture, supply, installation, use, maintenance and removal
- any claims by the manufacturer relating to CE marking.

19.6 Any information relating to the manufacture, supply, installation, use, maintenance and removal of this product/ system which is contained or referred to in this Certificate is the minimum required to be met when the product/system is manufactured, supplied, installed, used, maintained and removed. It does not purport in any way to restate the requirements of the Health and Safety at Work etc. Act 1974, or of any other statutory, common law or other duty which may exist at the date of issue or reissue of this Certificate; nor is conformity with such information to be taken as satisfying the requirements of the 1974 Act or of any statutory, common law or other duty of care.

©2016